BESPOKE INDUSTRIAL LTD
DESIGNED. MANUFACTURED. DELIVERED.

THE COMPLETE GUIDE TO INDUSTRIAL GAS CYLINDER STORAGE

A PRACTICAL GUIDE TO SAFE STORAGE, SECURITY, SEGREGATION AND BESPOKE STORAGE SOLUTIONS

SafeContractor APPROVED

SSIP

MADE IN BRITAIN



Introduction to Industrial Gas Cylinder Storage

Industrial gas cylinders are used across a wide range of industries, including manufacturing, engineering, fabrication, welding, construction, food production, healthcare and warehousing.

From compressed oxygen and nitrogen to argon, carbon dioxide, acetylene and propane, these gases play an important role in many everyday industrial processes.

However, storing gas cylinders incorrectly can introduce significant safety risks.

Cylinders may contain gases that are flammable, oxidising, toxic, corrosive or capable of causing asphyxiation. Even cylinders considered empty can retain residual gas and must continue to be handled and stored appropriately.

A properly designed gas cylinder storage area helps businesses:

- Reduce the risk of fire and explosion.
- Prevent unauthorised access to hazardous materials.
- Protect cylinders against accidental damage.
- Maintain good housekeeping and organisation.
- Separate incompatible gases.
- Improve workplace safety and operational efficiency.

Gas cylinder storage should never be treated simply as a matter of finding somewhere to keep cylinders. The location, construction, ventilation, security and management of the storage area all need to be considered.

This guide explores the key considerations when planning, specifying or improving industrial gas cylinder storage facilities.

Understanding the Risks Associated with Gas Cylinders

Gas cylinders are pressure vessels and can present several hazards if damaged, incorrectly stored or poorly managed.

Understanding these hazards is the first step towards developing a suitable storage arrangement.

Fire and explosion:

Flammable gases such as acetylene, hydrogen and propane can create a fire or explosion risk if released and allowed to accumulate in the presence of an ignition source.
Storage areas should therefore be located and designed to minimise the likelihood of gas accumulation and ignition.

Oxygen enrichment:

Oxygen is not itself flammable, but it supports combustion and can cause materials to ignite more easily and burn more intensely.
Oxygen cylinders must be protected from contamination, particularly oil and grease, and appropriately segregated from incompatible materials.

Asphyxiation:

Some gases, including nitrogen, argon and carbon dioxide, can displace oxygen in the surrounding atmosphere.
A leak in an enclosed or poorly ventilated space can create a potentially life-threatening atmosphere without obvious warning.

Cylinder damage:

Gas cylinders can be damaged through:

- Forklift and vehicle impact.
- Falling or overturning.
- Incorrect handling.
- Exposure to excessive heat.
- Corrosion and deterioration.
- Inadequate storage arrangements.

A damaged cylinder or valve can result in an uncontrolled gas release.

Unauthorised access:

Gas cylinders can present a security risk if accessible to unauthorised personnel.
Secure storage arrangements help reduce the likelihood of theft, tampering and inappropriate use.

Types of Industrial Gases and Their Storage Requirements

Different gases have different physical and chemical properties. Storage arrangements must reflect the hazards associated with the specific gases being held.

The following table provides an introductory overview.

Gas	Common applications	Principal hazards
Oxygen	Welding, cutting and medical applications	Oxidising
Acetylene	Welding and metal cutting	Highly flammable
Propane	Heating, forklifts and industrial processes	Highly flammable
Nitrogen	Manufacturing, food processing and purging	Asphyxiant
Argon	Welding and metal fabrication	Asphyxiant
Carbon dioxide	Food production, beverage systems and welding	Asphyxiant
Hydrogen	Industrial processing and specialist applications	Highly flammable
Helium	Testing, manufacturing and specialist applications	Asphyxiant

Why gas identification matters:

Before designing a storage area, businesses should establish:

- Which gases are being stored.
- The hazard classification of each gas.
- The number and size of cylinders.
- The maximum quantity held.
- Whether cylinders are full, empty or in use.
- Whether incompatible gases need separate storage.
- Whether additional controls are required for specialist gases.

Always consult the relevant Safety Data Sheets (SDS), gas supplier and competent safety professional when determining appropriate storage arrangements.

Specialist toxic, corrosive, pyrophoric and other high-hazard gases may require additional controls beyond those described in this guide.

Essential Principles of Safe Gas Cylinder Storage

The British Compressed Gases Association's Code of Practice CP44 provides important guidance for the storage of gas cylinders and bundles.
The general principles include suitable location, ventilation, security and appropriate separation distances.

Outdoor storage:

Outdoor storage is generally preferred because it allows released gases to disperse more readily.
Storage areas should be positioned away from unsuitable locations, including building openings, ignition sources, heavily trafficked areas and locations where escaping gas could accumulate.
Where indoor storage is proposed, additional controls and a specific risk assessment are necessary.

Adequate ventilation:

Adequate ventilation is essential to prevent gas build-up. Mesh panels can provide airflow and security, but the enclosure design and location must ensure effective ventilation.

Secure storage:

Gas cylinders should be protected against unauthorised access.
Suitable measures may include:

- Lockable access doors.
- Secure hinges and locking mechanisms.
- Restricted access arrangements.
- Suitable perimeter fencing or enclosures.

Cylinder stability:

Cylinders should be stored in a stable, upright position where required by the cylinder and gas supplier's instructions.
Suitable restraints, retaining chains or purpose-designed supports should be provided to prevent cylinders falling over.

Protection from heat and ignition sources:

Storage locations should be selected to minimise exposure to heat, flames, sparks and other ignition sources.
The risks associated with nearby activities, equipment and vehicle movements must be considered.

Separation distances:

Gas cylinder storage distances should be determined by relevant industry guidance and site-specific risk assessments, considering nearby buildings, boundaries, ignition sources, hazardous materials and occupied areas.

Gas Cylinder Storage Cages and Enclosures

Purpose-designed gas cylinder storage cages provide a practical way of organising and securing cylinders in industrial environments.

They can be manufactured in different sizes and configurations to accommodate individual cylinders, multiple cylinder types or larger storage requirements.

Common storage cage configurations

Single-cylinder storage:
Designed to accommodate a small number of cylinders, typically where individual cylinders need to be secured and protected.

Multi-cylinder storage cages:
Larger enclosures designed to accommodate multiple cylinders, with arrangements for organised storage and access.

Segregated storage enclosures:
Designed with separate compartments or designated storage areas where the risk assessment and applicable guidance require segregation.

Outdoor gas cylinder stores:
Purpose-designed enclosures incorporating suitable ventilation, secure access and weather-resistant construction.

Bespoke gas cylinder racks:
Designed around specific cylinder sizes, quantities and operational requirements, with suitable retaining arrangements.

Mesh versus solid construction
Mesh and solid steel construction each have potential applications.

Feature	Mesh construction	Solid steel construction
Natural ventilation	Allows airflow through panels	Requires separately designed ventilation
Visibility	Allows contents to be viewed	Limits visibility
Security	Can incorporate secure mesh panels and doors	Can provide a solid physical barrier
Weather protection	Limited	Can provide greater protection
Customisation	Highly adaptable	Highly adaptable
Typical application	Ventilated outdoor storage	Specific applications requiring additional enclosure or weather protection

For many outdoor industrial cylinder stores, appropriately designed mesh enclosures offer a useful combination of ventilation, security and visibility.
The choice of construction must always be appropriate for the gases being stored and the site-specific risk assessment.

Design Considerations for Industrial Gas Cylinder Storage

A gas cylinder storage enclosure should be designed around its intended application rather than selected solely on its external dimensions.

Several factors need to be considered before manufacture.

Overall dimensions:

The enclosure should provide sufficient space for the intended cylinder quantities and sizes.
Consider:

- Cylinder height and diameter.
- Number of cylinders.
- Access and handling requirements.
- Internal compartment arrangements.
- Space required for safe cylinder removal.
- Future storage requirements.

Structural construction:

The frame and panels should be suitable for the intended operating environment.

Potential construction materials include:

- Mild steel box section.
- Welded mesh panels.
- Fabricated steel frames.
- Steel plate base sections where appropriate.
- Galvanised or suitably coated steel components.

Material selection should consider corrosion exposure, anticipated service life, mechanical damage and maintenance requirements.

Doors and access:

Access arrangements should allow cylinders to be handled without unnecessary difficulty.

Design considerations include:

- Single or double-leaf hinged doors.
- Lockable access points.
- Suitable door openings.
- Secure hinges and locking arrangements.
- Safe access for cylinder replacement.
- Prevention of doors obstructing walkways or escape routes.

Design Considerations for Industrial Gas Cylinder Storage Continued...

Cylinder retention:

Cylinders should be restrained using suitable retaining systems.
Depending on the application, these may include:

- Individual retaining chains.
- Purpose-designed cylinder brackets.
- Adjustable restraint systems.
- Retaining rails.
- Dedicated cylinder support positions.

The restraint arrangement should be appropriate for the cylinder dimensions and foreseeable operating conditions.

Base and floor arrangements:

The supporting surface should be suitable for the total weight of the enclosure and its contents.
It should also provide a stable surface for cylinder storage and handling.

Where required by the design, a suitable base frame or floor arrangement can help define individual storage positions and protect the enclosure from localised damage.
Drainage, housekeeping and the potential for gas accumulation at low levels should also be considered.

Weather protection:

Outdoor storage areas may require protection against rain, snow and excessive environmental exposure.
Roofing or weather-protection features should not compromise ventilation or create locations where escaping gas can accumulate.

Vehicle impact protection:

Where forklifts, delivery vehicles or other mobile plant operate nearby, the risk of accidental impact must be assessed.

Suitable protection may include:

- External steel safety barriers.
- Vehicle-resistant bollards.
- Dedicated exclusion zones.
- Relocated storage positions.
- Physical separation from vehicle routes.

The required protection should be selected and verified against the foreseeable impact risk.

Gas Cylinder Segregation and Organisation

One of the most important considerations in gas cylinder storage is the appropriate segregation of different gas types.

Some gases can react dangerously with one another or increase the consequences of a fire or gas release. Storage arrangements should therefore reflect the hazards and compatibility of the substances being held.

Full and empty cylinders:

Full, empty and part-used cylinders should be identified and managed appropriately.

Empty cylinders should not automatically be considered harmless. They may retain residual gas and must continue to be stored and handled safely.

Clearly identified storage areas can help prevent confusion and improve stock control.

Separating incompatible gases:

Different categories of gas may require physical separation, separation distances or other protective measures. For example:

- Flammable gases and oxidising gases require appropriate segregation.
- Oxygen cylinders should be protected from oil, grease and combustible contamination.
- Toxic and corrosive gases may require dedicated specialist storage.
- Acetylene and other fuel gases require controls appropriate to their individual hazards.

The exact arrangements must be established using BCGA CP44, applicable specialist guidance and the site-specific risk assessment.

Labelling and identification:

Storage areas should use suitable signage to identify the gases present and communicate relevant hazards. Labels and warning signs may include:

- Flammable gas.
- Oxidising gas.
- Toxic gas.
- Asphyxiant gas.
- No smoking.
- No naked flames.
- Authorised personnel only.

Cylinder identification should always be maintained in accordance with the relevant supplier and regulatory requirements.

Security and Protection Against Damage

Security and physical protection are important aspects of any industrial gas cylinder storage installation.

A suitable enclosure should help prevent unauthorised access while reducing foreseeable risks of damage.

Access control:

Depending on the site, security measures may include:

- Lockable mesh doors.
- Heavy-duty hinges.
- Secure locking arrangements.
- Restricted access.
- Controlled key management.

Protection against mechanical damage:

Storage locations should be assessed for the possibility of impact from:

- Forklift trucks.
- Pallet trucks.
- Delivery vehicles.
- Loading equipment.
- General site traffic.

Where necessary, protective barriers should be installed independently of the storage enclosure.

Corrosion protection:

Outdoor steel structures can be exposed to moisture, changing temperatures and industrial environments. Appropriate protective finishes may include:

- Hot-dip galvanising.
- Suitable industrial paint systems.
- Powder coating where appropriate.

The selected finish should be suitable for the exposure conditions and intended maintenance arrangements.

Handling, Inspection and Maintenance

Safe storage does not end once a gas cylinder enclosure has been installed.

Businesses should establish appropriate inspection and maintenance procedures to ensure the storage arrangement remains suitable.

Routine visual inspections:

Checks should include:

- Condition of the enclosure and structural frame.
- Door hinges, locks and locking mechanisms.
- Condition of mesh panels and fixings.
- Cylinder restraints and supports.
- Signs of corrosion or damage.
- General housekeeping.
- Visibility and condition of warning signage.
- Obstructions affecting ventilation.
- Evidence of unauthorised access.

Cylinder handling:

Gas cylinders should be handled by trained personnel using suitable equipment and procedures.

Cylinders should be protected against falling, impact and valve damage during movement.

Where mechanical handling equipment is used, the movement route and storage arrangement should be assessed.

Inspection records:

Businesses should maintain suitable records of inspections, identified defects and corrective actions.

The frequency of inspections should be established through the risk assessment and site management arrangements.

UK Regulations, Standards and Industry Guidance

Businesses storing industrial gas cylinders in the UK must consider the relevant health, safety and fire legislation and applicable industry guidance.

The following are particularly relevant.

Dangerous Substances and Explosive Atmospheres Regulations 2002 (DSEAR):
DSEAR requires employers and the self-employed to assess and control risks arising from dangerous substances in the workplace.
This includes risks associated with flammable gases, fires, explosions and potentially explosive atmospheres.
The assessment should consider the substances present, quantities, storage arrangements, ignition sources and appropriate control measures.

Health and Safety at Work etc. Act 1974:

Establishes general duties to protect employees and others who may be affected by work activities.

Management of Health and Safety at Work Regulations 1999:
Require suitable and sufficient risk assessments and appropriate arrangements for managing workplace health and safety.

Regulatory Reform (Fire Safety) Order 2005:
Applies in England and Wales and places duties on the responsible person to assess and manage fire risks in relevant premises.

P**rovision and Use of Work Equipment Regulations 1998 (PUWER):**
May apply to equipment used in the handling and movement of gas cylinders.

Relevant industry guidance

BCGA CP44 – The Storage of Gas Cylinders:
An important industry Code of Practice covering the safe storage of gas cylinders and bundles.
It provides guidance on storage location, construction, management, hazards and separation.

BCGA CP40 – Security Requirements for the Industrial, Medical and Food Gases Industry:
Provides guidance on security arrangements for industrial, medical and food gases.

BCGA GN13 – DSEAR Risk Assessment Guidance for Compressed Gases:
Provides guidance on assessing risks associated with compressed gases under DSEAR.

HSE L138 – Dangerous Substances and Explosive Atmospheres:
The HSE Approved Code of Practice and guidance covering DSEAR.

Businesses should always consult the latest applicable publications and obtain competent advice where necessary.

Choosing the Right Gas Cylinder Storage Solution

Selecting an appropriate storage solution requires consideration of both the cylinders being stored and the operational environment.

Before purchasing or commissioning a new enclosure, businesses should consider the following questions.

Storage requirements:

- Which gases will be stored?
- How many cylinders are required?
- What are the cylinder dimensions?
- Will full and empty cylinders be stored separately?
- Are there incompatible gases requiring segregation?

Location:

- Will the enclosure be installed indoors or outdoors?
- Is there sufficient ventilation?
- Are there nearby buildings, doors, windows or air intakes?
- Are there ignition sources nearby?
- Are separation distances achievable?

C**onstruction:**

- Is mesh or solid construction appropriate?
- Is a roof required?
- What level of corrosion protection is needed?
- Are separate compartments required?
- What security arrangements are necessary?

Operational requirements:

- How will cylinders be loaded and unloaded?
- Will forklift trucks operate nearby?
- Is additional impact protection required?
- How will cylinders be restrained?
- Will the storage arrangement need to accommodate future expansion?

Taking the time to establish these requirements before manufacture can help avoid unsuitable installations and unnecessary modifications.

Common Gas Cylinder Storage Problems

Many industrial facilities operate with storage arrangements that have developed gradually over time.

This can result in problems that may not become apparent until a workplace review or safety inspection takes place.

Common examples include:

Inadequate storage capacity

Cylinders are stored outside designated areas because the original enclosure no longer meets operational requirements.

Poor organisation

Full, empty and different gas types are stored together without sufficient identification or segregation.
Insufficient security
Cylinders are accessible to unauthorised personnel because existing fencing or storage arrangements are inadequate.

Poor ventilation

Enclosures or storage locations restrict natural airflow and may allow released gases to accumulate.

Physical damage

Cages, doors and panels become damaged through repeated contact with forklifts or other equipment.

Unsuitable storage locations

Storage areas are positioned too close to buildings, entrances, ignition sources or vehicle routes.

Inadequate cylinder restraints
Cylinders are not adequately secured against falling or overturning.

Identifying these issues provides an opportunity to review the existing arrangement and introduce more suitable storage solutions.

Gas Cylinder Storage Checklist

The following checklist can be used as an initial prompt when reviewing an industrial gas cylinder storage area.

Inspection point	Check
Storage location has been assessed	☐
Suitable ventilation is provided	☐
Storage area is appropriately secured	☐
Gas types have been identified	☐
Incompatible gases are appropriately segregated	☐
Full and empty cylinders are identified	☐
Cylinders are adequately restrained	☐
Warning signs are displayed	☐
Ignition sources have been considered	☐
Separation distances have been assessed	☐
Vehicle impact risks have been assessed	☐
Access doors and locks are serviceable	☐
Enclosure is free from significant damage	☐
Corrosion and deterioration are monitored	☐
Emergency arrangements are in place	☐
Relevant risk assessments are available	☐
Staff have suitable training and instruction	☐

Important: This checklist is an initial review aid, not a substitute for a competent risk assessment or a detailed assessment against BCGA CP44 and other applicable requirements.

How Bespoke Industrial Can Help

Bespoke Industrial Gas Cylinder Storage Solutions

Every industrial site has different storage requirements.

The number of cylinders, types of gases, available space, operating environment and security requirements can all influence the design of a suitable storage solution.

At Bespoke Industrial Ltd, we provide bespoke engineering and manufacturing solutions for businesses requiring practical, durable and purpose-designed industrial equipment.

Our capabilities include:

- Bespoke gas cylinder storage cages.
- Welded mesh storage enclosures.
- Steel-framed storage systems.
- Lockable access doors and gates.
- Segregated storage compartments.
- Bespoke cylinder racks and retaining systems.
- Customised industrial safety enclosures.

We work with businesses to understand their requirements and develop storage solutions suited to their individual applications.

Whether you require a compact cylinder storage cage or a larger outdoor storage enclosure, we can help develop a solution around your operational needs.

Need a bespoke gas cylinder storage solution?

If your existing gas cylinder storage arrangements need improving, or you are planning a new installation, Bespoke Industrial can help.

We welcome enquiries from manufacturers, engineering companies, warehouses and industrial facilities across Yorkshire and surrounding areas.

Contact Bespoke Industrial Ltd
Website: www.bespokeindustrial.co.uk
Tel: 01422 771460
Email: mail@bespokeindustrial.co.uk

Bespoke Industrial Lrd, Elsie Whiteley Innovation Centre, Hopwood Lane, Halifax, West Yorkshire, HX1 5ER

BESPOKE INDUSTRIAL LTD
DESIGNED. MANUFACTURED. DELIVERED.

Important Information and Disclaimer

This guide is intended for general information and educational purposes.
It does not constitute a site-specific risk assessment, engineering specification, legal advice or certification of compliance.

The suitability of any gas cylinder storage arrangement must be established through an appropriate assessment of the gases, quantities, location, construction, ventilation, separation distances, security and operating conditions.

Businesses should consult competent health and safety professionals, gas suppliers and relevant authorities where appropriate.

Always refer to the latest applicable legislation, HSE guidance and BCGA publications before specifying or installing a gas cylinder storage facility.

Technical references:

- British Compressed Gases Association – CP44, The Storage of Gas Cylinders.
- British Compressed Gases Association – CP40, Security Requirements.
- Health and Safety Executive – L138, Dangerous Substances and Explosive Atmospheres.
- Health and Safety Executive – DSEAR guidance.

Guide produced by Bespoke Industrial Ltd | November 2026











BESPOKE INDUSTRIAL LTD
DESIGNED. MANUFACTURED. DELIVERED.